

TAMILNADU FIRE & RESCUE SERVICES

R.C.No: 207/V/CHEYYUR/ 2026
Date: 10.08.2026



Fire & Rescue Station
Cheyyur

NO OBJECTION CERTIFICATE

Subject: Fire and Rescue services - FIRE & RESCUE STATION, CHEYYUR -
Obtained Fire NOC


Notice: 1. Gov . Order No:122 ,School Education (2) Dept. Pay: 14.09.2004
2. Gov . Order No:123 ,School Education (2) Dept. Pay: 14.09.2004
3. Application Received From the Principal
M/s. MARG NAVAJYOTHI VIDYALAYA SCHOOL (CBSE), Date : 03.08.2026

As per the Govt. order and application **M/s. MARG NAVAJYOTHI VIDYALAYA SCHOOL (CBSE) G+2.** Situated at **S.No:95/1B, 95/3, 93/4, 94P&93/3, VELUR VILLAGE, SEEKANANKUPPAM, CHEYYUR TALUK, CHENGALPATTU DISTRICT,** was inspected by the **Mr.A.AMAL DOSS**, Station officer CHEYYUR, On **04.08.2026**. There is No Objection from the Department of Fire and Rescue Services a school building at this place or to issue school recognition.

CONDITIONS

1. As per National Building Code of India 2005, Part- IV Fire and life Safety , Periodical Maintenance and care should be to all Fire protection equipments with good working condition at all times and a register should be Maintained.
2. The First Aid Fire fighting equipments should be Maintained at all floors in accordance with the ISO : 2190:2010 requirements.
3. If there is deviation from the Government Rules and Act , the NOC issued will be cancelled.
4. This NOC valid for one year from the date of issue.
5. Elementary fire fighting training should be given to the employees from fire service department




FIRE OFFICER
FIRE & RESCUE STATION
CHEYYUR - 603 302

To:
M/s. MARG NAVAJYOTHI VIDYALAYA SCHOOL (CBSE),
S.No:95/1B, 95/3, 93/4, 94P&93/3, VELUR VILLAGE,
SEEKANANKUPPAM, CHEYYUR TALUK,
CHENGALPATTU DISTRICT-603 302.

Copy to :

1. The district Officer , Chengalpat
Concerned Licence Officer