

# TAMILNADU FIRE & RESCUE SERVICES

R.C.No: 205/V/CHEYYUR/ 2025

Date: 18.08.2025



Fire & Rescue Station  
Cheyyur

## NO OBJECTION CERTIFICATE

Subject: Fire and Rescue services - FIRE & RESCUE STATION, CHEYYUR -  
Obtained Fire NOC

Notice: 1. Gov. Order No:122 ,School Education (2) Dept. Pay: 14.09.2014  
2. Gov. Order No:123 ,School Education (2) Dept. Pay: 14.09.2014  
3. Application Received From the Principal  
**M/s. MARG NAVAJYOTHI VIDYALAYA SCHOOL (CBSE), Date : 06.08.2025**

As per the Govt. order and application M/s. MARG NAVAJYOTHI VIDYALAYA SCHOOL (CBSE) G+2, Situated at S.No:95/1B, 95/3, 93/4, 94P&93/3, VELUR VILLAGE, SEEKANANKUPPAM, CHEYYUR TALUK, CHENGALPATTU DISTRICT, was inspected by the Mr .A.AMAL DOSS, Station officer CHEYYUR, On 13.08.2025. There ia No Objection from the Department of Fire and Rescue Services a school building at this place or to issue school recognition.

## CONDITIONS

1. As per National Buildig Code of India 2005,Part- IV Fire and life Safety , Periodical Maintenance and care should be to all Fire protection equipments with good working condition at all times and a register should be Maintained.
2. The First Aid Fire fighting equipments should be Maintained at all floors in accordance with the ISO : 2190:2010 requirements.
3. If threr is deviation from the Government Rules and Act , the NOC issued will be cancelled.
4. This NOC valid for one year from the date of issuus.
5. Elementary fire fighting training should be given to the employees from fire service department



  
FIRE OFFICER  
FIRE & RESCUE STATION  
CHEYYUR - 603 302

To:

M/s. MARG NAVAJYOTHI VIDYALAYA SCHOOL (CBSE),  
S.No:95/1B, 95/3, 93/4, 94P&93/3, VELUR VILLAGE,  
SEEKANANKUPPAM, CHEYYUR TALUK,  
CHENGALPATTU DISTRICT-603 302.

Copy to :

1. The district Officer , Chengalpat  
Concerned Licence Officer